

**State of Oregon
Building Codes Division
Interpretive Ruling No. 03-3**

JENSEN PRECAST

Initiated By: Brett Black
Jensen Precast
62960 Boyd Acres Road
Bend, OR 97701-8237
(541) 382-0342

REQUEST FOR RULING

Approval of the Model G2 - 24"x 24" reinforced concrete catch basin with integral trap and steel grate.

APPLICABLE CODE SECTION

Oregon Plumbing Specialty Code, 2000 Edition, Section 1108.0, Catch Basin Specifications.

FINDINGS


Catch basins for traffic areas are required to meet the provisions of AASHTO H-20. Catch basin grates must meet the provisions of Oregon Plumbing Specialty Code, 2000 Edition, Section 1108.4.

RULING

When installed properly within the limitations of this ruling and the Oregon Plumbing Specialty Code, the use of the above product is equivalent to that prescribed for catch basins.

CONCLUSION


The State Plumbing Board recommends the Building Codes Administrator approve this Interpretive Ruling No. 03-3.



Lewis E. Seagraves
Chairman, Plumbing Board

April 18, 2003
Date

The recommendations and findings of the State Plumbing Board are accepted and Interpretive Ruling No. 03-3 is approved.



Mark S. Long
Administrator, Building Codes Division

5/27/03
Date